

# HARRIS COUNTY M.U.D. No. 370

PWS ID # 1013113

## 2024 Annual Drinking Water Quality Report

Phone No: 281-350-0895

### *En Español*

*Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en espanol, por favor llame al telefono 281-350-0895.*

This report is a summary of the quality of the water we provide to our customers. The analysis was made by using the data from the most recent Environmental Protection Agency (EPA) required tests and is presented in the following tables. We hope this information helps you become more knowledgeable about your drinking water.

**Public Participation Opportunities** concerning your water system may be made at regularly scheduled meetings on the second Monday of each month at 12:00 p.m., Schwartz, Page & Harding, L.P., 1300 Post Oak Blvd, Suite 2500, Houston, Texas, 77056. You may contact Tarynn Fossati with TNG Utility Corp., phone # 281-350-0895, with any questions or concerns you may have.

### Where do we get your drinking water?

Our drinking water is obtained from groundwater as well as surface water sources. Our groundwater comes from water-bearing sands known as the Evangeline Aquifer. Our surface water comes from the West Harris County Regional Water Authority, which provides surface water from the Trinity River located in Harris County.

The Texas Commission of Environmental Quality completed an assessment of our source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for our water system are based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Tarynn Fossati with TNG Utility at 281-350-0895.

**Water Sources:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (i) microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; (ii) inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (iii) pesticides and herbicides, which might have a variety of sources such as agriculture, urban storm water runoff, and residential uses; (iv) organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm-water runoff, and septic systems; and (v) radioactive contaminants, which can be naturally-occurring or the result of oil and gas production and mining activities.

### **A Special Notice for the Elderly, Infants, Cancer Patients, people with HIV/AIDS or other immune Problems:**

You may be more vulnerable than the general population to certain microbial contaminants, such as **Cryptosporidium**, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791). Also, see EPA website: [www.epa.gov/safewater](http://www.epa.gov/safewater) and NRDC website: [www.nrdc.org/water](http://www.nrdc.org/water)

### **All Drinking Water May Contain Contaminants**

When drinking water meets federal standards there may not be any health-based benefits to purchasing bottled water or point of use devices.

Drinking water, *including bottled water*, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800-426-4791).

In order to ensure that the tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water please contact the system's business office.

### **Lead Service Line Inventory Statement**

As part of the U.S. Environmental Protection Agency's (EPA) revised Lead and Copper Rule, Harris County MUD 370 has completed a full inventory of service lines within the water distribution system, including the utility-owned and customer-owned portions of each service connection. Based on historical records, and material verification, no lead or galvanized service lines requiring replacement were identified. All service lines are confirmed to be made of non-lead materials such as copper, plastic, or other EPA-approved materials. If you have any questions regarding your service line material or would like to view our inventory, please contact Tarynn Fossati at 281-350-0895.



TNG UTILITY CORP. PWS ID # 1013113

### ***About the Following Table***

The following table contains all of the federally regulated or monitored chemical constituents which have been found in your drinking water. EPA requires water systems to test up to 97 constituents. The data presented in the report is from the most recent testing done in accordance with the regulations.

### ***Abbreviations and Definitions***

**Avg:** Regulatory compliance with some MCLs are based on running annual average of monthly samples.

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Maximum Contaminant Level Goal (MCLG)** - The level of contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of use of disinfectants to control microbial contamination.

**Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Action Level Goal (ALG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

**MFL:** million fibers per liter (measure of asbestos)

**ppm** - milligrams per liter or parts per million-or one ounce in 7,350 gallons of water.

**ppb** - micrograms per liter or parts per billion-or one ounce in 7,350,000 gallons of water.

**pCi/L** - pico curies per liter (a measure of radioactivity)

**N/A** - not applicable

**mrrem** - millirems per year (a measure of radiation absorbed by the body)

**NTU**-nephelometric turbidity units (a measure of turbidity)

**ppt**-parts per trillion, or nanograms per liter (ng/L)

**ppq**-parts per quadrillion, or picograms per liter (pg/L)

### ***Harris County M.U.D. No. 370 - 2024 Drinking Water Quality Report Data***

| Disinfectants and Disinfection By-Products | Collection Date | Highest Level Detected | Range of Individual Detected | MCLG                  | MCL | Units | Violation | Likely Source of Contamination             |
|--|-----------------|------------------------|------------------------------|-----------------------|-----|-------|-----------|--|
| *Haloacetic Acids (HAA5)                   | 2024            | 20                     | 3.3 – 50.3                   | No goal for the total | 60  | ppb   | N         | By-product of drinking water disinfection. |
| *Total Trihalomethanes (TTHM)              | 2024            | 22                     | 7.4 – 41.7                   | No goal for the total | 80  | ppb   | N         | By-product of drinking water disinfection. |

| Inorganic Contaminants         | Collection Date | Highest Level Detected | Range of Individual Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination   |
|--------------------------------|-----------------|------------------------|------------------------------|------|-----|-------|-----------|--|
| Asbestos                       | 2022            | 0.197                  | 0.197 - 0.197                | 7    | 7   | MFL   | N         | Decay of asbestos cement water mains; Erosion of natural deposits.   |
| Barium                         | 2022            | 0.0609                 | 0.0609 - 0.0609              | 2    | 2   | ppm   | N         | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.                                |
| Cyanide                        | 2024            | 190                    | 0 - 190                      | 200  | 200 | ppb   | N         | Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.                                     |
| Fluoride                       | 2024            | 0.48                   | 0.48 - 0.48                  | 4    | 4.0 | ppm   | N         | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Nitrate [measured as Nitrogen] | 2024            | 0.08                   | 0.08 - 0.08                  | 10   | 10  | ppm   | N         | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.                               |

| Radioactive Contaminants | Collection Date | Highest Level Detected | Range of Individual Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--------------------------|-----------------|------------------------|------------------------------|------|-----|-------|-----------|--------------------------------|
| Combined Radium 226/228  | 2022            | 1.5                    | 1.5 - 1.5                    | 0    | 5   | pCi/L | N         | Erosion of natural deposits.   |

\*The value in the Highest Level or Average Detected column is the highest average of all TTHM and HAA5 sample results collected at a location over a year.



PWS ID # 1013113

**Harris County M.U.D. No. 370 - 2024 Drinking Water Quality Report Data Continuation**

| Disinfectant type and unit of measure | Year Sampled | Average Level | Minimum Level | Maximum Level | MRDL | MRDLG | Units | Violation | Likely Source of Contamination           |
|---------------------------------------|--------------|---------------|---------------|---------------|------|-------|-------|-----------|--|
| Chloramine (Total)                    | 2024         | 2.57          | 0.52          | 4.0           | 4.00 | 4.00  | ppm   | No        | Water additive used to control microbes. |

| Synthetic organic contaminants including pesticides and herbicides |  | Collection Date | Highest Level Detected | Range of Individual Samples | MCLG | MCL | Units | Violation | Likely Source of Contamination            |
|--|--|-----------------|------------------------|-----------------------------|------|-----|-------|-----------|---|
| Atrazine   |  | 2023            | 0.13                   | 0.13 - 0.13                 | 3    | 3   | ppb   | N         | Runoff from Herbicides used on row crops. |
| Simazine   |  | 2023            | 0.12                   | 0.12 - 0.12                 | 4    | 4   | ppb   | N         | Herbicide runoff.                         |

| Lead and Copper | Date Sampled | MCLG | Action Level (AL) | 90th Percentile | # Sites Over AL | Units | Violation | Likely Source of Contamination  |
|-----------------|--------------|------|-------------------|-----------------|-----------------|-------|-----------|---|
| Copper          | 2024         | 1.3  | 1.3               | 0.73            | 0               | ppm   | N         | Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems. |
| Lead            | 2024         | 0    | 15                | 1.83            | 1               | ppb   | N         | Corrosion of household plumbing systems; Erosion of natural deposits.                                   |

**Recommended Additional Health Information for Lead in Drinking Water:**

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in home plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested by an approved laboratory. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."

**Unregulated Contaminant Monitoring Rule (UCMR):**

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. As our customers, you have a right to know that these results are available. If you are interested in examining the results, please contact Tarynn Fossati at 281-350-0895.

| Unregulated Contaminant            | Collection Date | Average Level (µg/L) | Range of Levels Detected (µg/L) | Health-Based Reference Concentration (µg/L) | Health Information Summary   |
|------------------------------------|-----------------|----------------------|---------------------------------|---|--|
| Perfluorobutanesulfonic acid, PFBS | 2023            | 0.0034               | 0.0034 - 0.0034                 | 2   | This data is part of UCMR5 results in relation to minimum reporting levels and available non-regulatory health-based reference concentrations. |
| Perfluorohexanoic acid, PFHxA      | 2023            | 0.0049               | 0.0049 - 0.0049                 | N/A   | This data is part of UCMR5 results in relation to minimum reporting levels and available non-regulatory health-based reference concentrations. |
| Perfluoropentanoic acid, PFPeA     | 2023            | 0.0053               | 0.0053 - 0.0053                 | N/A   | This data is part of UCMR5 results in relation to minimum reporting levels and available non-regulatory health-based reference concentrations. |
| Lithium                            | 2023            | 23.06                | 12.2 - 30.5                     | 10  | This data is part of UCMR5 results in relation to minimum reporting levels and available non-regulatory health-based reference concentrations. |



PWS ID # 1013113

## **Harris County M.U.D. No. 370 - 2024 Drinking Water Quality Report Data Continuation**

**Harris County M.U.D. 370 has an active Interconnect with Harris County M.U.D. 341 that is used for Emergencies. This interconnect was not used during 2023. For more water quality information call Tarynn Fossati at TNG Utility at 281-350-0895.**

**Harris County M.U.D. 370 purchases surface water from West Harris County Regional Water Authority mandated under Harris Galveston Subsidence District and below are the constituents' levels for the water they supply. For more water quality information call the West Harris County Regional Water Authority at 713-860-6400.**

### **Coliform Bacteria**

| Maximum Contaminant Level Goal | Total Coliform Maximum Contaminant Level | Highest No. of Positive | Fecal Coliform or E. Coli Maximum Contaminant Level | Total No. of Positive E. Coli or Fecal Coliform Samples | Violation | Likely Source of Contamination        |
|--------------------------------|--|-------------------------|---|---|-----------|---------------------------------------|
| 0                              | 5% of monthly samples are positive.      | 1.4                     | NA  | 0   | N         | Naturally present in the environment. |

| Lead and Copper | Date Sampled | MCLG | Action Level (AL) | 90th Percentile | # Sites Over AL | Units | Violation | Likely Source of Contamination  |
|-----------------|--------------|------|-------------------|-----------------|-----------------|-------|-----------|---|
| Copper          | 2024         | 1.3  | 1.3               | 0.251           | 1               | ppm   | N         | Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems. |
| Lead            | 2024         | 0    | 15                | 5               | 5               | ppb   | N         | Corrosion of household plumbing systems; Erosion of natural deposits.                                   |

| Inorganic Contaminants         | Collection Date | Highest Level Detected | Range of Individual Samples | MCLG | MCL | Units | Violation | Likely Source of Contamination   |
|--------------------------------|-----------------|------------------------|-----------------------------|------|-----|-------|-----------|--|
| Arsenic                        | 2024            | 2                      | 0 – 9.9                     | 0    | 10  | ppb   | N         | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.                    |
| Barium                         | 2024            | 0.357                  | 0.0385 – 0.357              | 2    | 2   | ppm   | N         | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.                                |
| Cyanide                        | 2024            | 200                    | 0 – 200                     | 200  | 200 | ppb   | N         | Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.                                     |
| Fluoride                       | 2024            | 0.2                    | 0.11 – 0.28                 | 4    | 4.0 | ppm   | N         | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Nitrate [measured as Nitrogen] | 2024            | 1.0                    | 0 - 0.95                    | 10   | 10  | ppm   | N         | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.                               |



## Harris County M.U.D. No. 370 - 2024 Drinking Water Quality Report Data Continuation

| Disinfection By-Products     | Collection Date | Highest Level Detected | Range of Individual Samples | MCLG                  | MCL | Units | Violation | Likely Source of Contamination             |
|------------------------------|-----------------|------------------------|-----------------------------|-----------------------|-----|-------|-----------|--|
| Haloacetic Acids (HAA5)      | 2024            | 30                     | 0 – 50.4                    | No goal for the total | 60  | ppb   | N         | By-product of drinking water disinfection. |
| Total Trihalomethanes (TTHM) | 2024            | 37                     | 0 – 48.5                    | No goal for the total | 80  | ppb   | N         | By-product of drinking water disinfection. |

| Radioactive Contaminants                | Collection Date | Highest Level Detected | Range of Individual Samples | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|---|-----------------|------------------------|-----------------------------|------|-----|-------|-----------|--------------------------------|
| Combined Radium 226/228                 | 2024            | 1.91                   | 1.63 – 1.91                 | 0    | 60  | ppb   | N         | Erosion of natural deposits.   |
| Gross alpha excluding radon and uranium | 2024            | 7.1                    | 6.8 – 7.1                   | 0    | 80  | ppb   | N         | Erosion of natural deposits.   |

| Synthetic organic contaminants including pesticides and herbicides | Collection Date | Highest Level Detected | Range of Individual Samples | MCLG | MCL | Units | Violation | Likely Source of Contamination            |
|--|-----------------|------------------------|-----------------------------|------|-----|-------|-----------|---|
| Atrazine   | 2024            | 2.0                    | 0 – 2.3                     | 3    | 3   | ppb   | N         | Runoff from Herbicides used on row crops. |
| Simazine   | 2024            | 0.14                   | 0 - 0.14                    | 4    | 4   | ppb   | N         | Herbicide runoff.                         |

### Turbidity

|                                | Level Detected | Limit (Treatment Technique) | Violation | Likely Source of Contamination |
|--------------------------------|----------------|-----------------------------|-----------|--------------------------------|
| Highest single measurement     | 0.8 NTU        | 1 NTU                       | N         | Soil runoff.                   |
| Lowest monthly % meeting limit | 99%            | 0.3 NTU                     | N         | Soil runoff.                   |

Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

### Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set.

